



Loudoun County, Virginia

Department of Finance and Procurement
Division of Procurement
1 Harrison Street, SE, 4th Floor
Leesburg, Virginia 20175
www.loudoun.gov/procurement

April 24, 2019

NOTICE TO BIDDERS

ADDENDUM NO. 2

RFQ 75776

The following changes and/or additions shall be made to the original Invitation for Bid No. RFQ 75776, The Moorefield Station Neighborhood Park. Please acknowledge receipt of this addendum by signing and returning with your bid.

1. Questions and answers related to the IFB are attached.
2. Attachment 1 to this addendum: Updated sheet 50, showing additional notes and "Approval as Noted by Jeremy Jerden, EIT, August 15, 2018"
3. Attachment 2 to this addendum: CG Guidelines Letter for crossing over the existing gas main.

Prepared By: s/Cheryl L. Middleton, CPPB Date: 4/25/19
Purchasing Agent

Acknowledged By: _____ Date: _____

Questions and Answers

Q1. Keynote 5 on sheet 50 (E-2) states that site lights to be provided and installed by power company, please clarify the following:
- General contractor is only responsible for rough in, including empty conduit and junction boxes, no wire.

A. *That is correct, additionally the contractor is responsible for providing pull strings.*

Site lights including poles and foundations by others, if not please provide light pole foundations details.

A. *The site lights utilize lights and poles by dominion. No base is required.*

Q2. Please provide a specification and model number of the enclosure described in keynote 3 on sheet 50 (E-2). Little buildings Inc. has quite a bit of different type of enclosures and not enough details is provided. Please clarify.

A. *The model number is #812.*