



Loudoun County, Virginia

Division of Procurement
One Harrison St, SE, 4th Floor
Leesburg, Virginia 20175

May 11, 2021

NOTICE TO BIDDERS

ADDENDUM NO. 1

RFQ 381782

The following changes and/or additions shall be made to the original Invitation for Bid RFQ 381782– Renovations to the Round Hill Aquatic Center. Please acknowledge receipt of this addendum by signing and returning with your bid.

1. The Purpose of this addendum is to provide additional information to potential bidders.

Prepared By: Farah Navder Date: May 11, 2021
Contracting Officer

Acknowledged By: _____ Date: _____

BEGINNING OF QUESTIONS

Q1: Please confirm one hour rated corridor showing in drawings is existing.

A1. Confirmed

Q2: Please confirm that equipment can be stored on site before start of construction.

A2: Materials can be stored on site in a container after NTP and the site being closed to the public. The contractor should assume all responsibility for the stored material. Location of the storage container will be finalized after contract award.

Q3. Please confirm the pool will be open for regular operations during construction.

A3: Please see 011000, 1.5 Use of Premises.

Q4; Please confirm hours of work.

A4: Please see 011000, 1.6 Work Restrictions.

Q5: Is there a Controls Contractor that is required for this project or is it stand-alone? If so, please provide the company, contact, and telephone number.

A5. Stand-alone control system provided by vendor.

Q6: Please confirm that hot water system does not contain glycol.

A6: The County was not able to confirm the presence of glycol in the hot water system, therefore, Contractors should assume glycol is present and recover accordingly.

END OF QUESTIONS