

December 3, 2021

NOTICE TO BIDDERS

ADDENDUM NO. 3

RFQ 443782

The following changes and/or additions shall be made to the original Invitation for Bid No. RFQ 443782: Dulles South Recreation Center Phase 5 Pool Filter Upgrades. Please acknowledge receipt of this addendum by signing and returning with your bid.

1. The purpose of this Addendum is to respond to questions received.

Prepared By: s/Farah Navder Date: 12/03/2021
Contracting Officer

Acknowledged By: _____ Date: _____

BEGIN QUESTIONS AND ANSWERS

Q1: Acceptable location to backwash water or pipe that we are to connect the backwash line to that meets county code requirements?

A1: The back wash lines are shown on drawing P201 discharging to the same drains to which the filters originally discharged. Refer to Keyed Notes 23 and 31. These existing drains are connected to a building drain that is labeled on the existing drawings as "8" sanitary for pool water". On drawing P201 this is the line identified as the "existing 8" pool drain" leaving the building.

Q2: Should we have an alternate in our bid for regenerative media for new filters?

A2: NO, LC will not change base of design on regenerative media for new filters.

END QUESTIONS AND ANSWERS